

Bridging Duct on Subfloor

Tate Access Floors, Inc.
7510 Montevideo Road
Jessup, MD 20794
Tel (410) 799-4200
Fax (410) 799-4207

Tate[®]

Structural steel channel size to be determined by grade of floor panel and length of span.

Channel sizes to support ConCore 1250 panels over 48" span:

Option 1: C6 X 13 (Flange width is 2.157")
Option 2: C7 X 9.8 (Flange width is 2.09")

Hole drilled through channel for installation of pedestal head which is fastened with (2) adjustment nuts and (2) 2-1/4" X 1/8" washers

